



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Clarksville Subdivision Distribution System

2016 ANNUAL/SUMMARY REPORT

Prepared by the Ontario Clean Water Agency
on behalf of the Municipality of Charlton and Dack



Table of Contents

INTRODUCTION 2

Section 11 - ANNUAL REPORT 3

 1.0 Introduction..... 3

 2.0 Description of the Drinking Water System (DWS No. 260078741) 4

 3.0 List of Water Treatment Chemicals Used Over the Reporting Period..... 6

 4.0 Significant Expenses Incurred in the Drinking Water System 6

 5.0 Drinking Water System Highlights..... 6

 6.0 Details on Notices of Adverse Test Results and Other Problems Reported to &
 Submitted to the Spills Action Center 6

 7.0 Microbiological Testing Performed During the Reporting Period 7

 8.0 Operational Testing Performed During the Reporting Period 7

CONCLUSION..... 9

List of Appendices

APPENDIX A – Monthly Summary of Microbiological and Chlorine Residual Results



INTRODUCTION

Municipalities throughout Ontario have been required to comply with Ontario Regulation 170/03 made under the Safe Drinking Water Act (SDWA) since June 2003. The Act was enacted following recommendations made by Commissioner O'Conner after the Walkerton Inquiry. The Act's purpose is to protect human health through the control and regulation of drinking water systems. O. Reg. 170/03 regulates drinking water testing, use of licensed laboratories, treatment requirements and reporting requirements.

Section 11 of Regulation 170/03 requires the owner to produce an Annual Report. This report must include the following:

1. Description of system & chemical(s) used
2. Summary of any adverse water quality reports and corrective actions
3. Summary of all required testing
4. Description of any major expenses incurred to install, repair or replace equipment

This annual report must be completed by February 28th of each year.

The Ontario Clean Water Agency (OCWA) prepared the 2016 Annual Report on behalf of the Owner Representative, the Municipality of Charlton and Dack.



Clarksville Subdivision Distribution System

Section 11

2016 ANNUAL REPORT



Section 11 - ANNUAL REPORT

1.0 Introduction

Drinking-Water System Name: CLARKSVILLE SUBDIVISION DISTRIBUTION SYSTEM
Drinking-Water System No.: 260078741
Drinking-Water System Owner: Each property owner of the Clarksville Subdivision (Owner Representative is The Corporation of the Municipality of Charlton & Dack)
Drinking-Water System Category: Non-Municipal Year-Round Residential System
Period being reported: January 1, 2016 to December 31, 2016

Number of Designated Facilities served: zero (0)

Did you provide a copy of your annual report to all Designated Facilities you serve? Not applicable

Number of Interested Authorities you report to: zero (0)

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Not applicable

Location where Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Municipality of Charlton & Dack
#287237 Spruce Grove Road
Englehart ON P0J 1H0

The Municipality of Charlton’s web site at <http://www.charltonanddack.com/>

Drinking Water Systems that receive drinking water from the Clarksville Subdivision Distribution System

The Clarksville Subdivision does not provide drinking water to any other system.

The Annual Report was provided to all other Connected Drinking Water System Owners.

The Ontario Clean Water Agency prepared the 2016 Annual Report for the Clarksville Subdivision Distribution System and provided a copy to the representative of the system owner; the Municipality of Charlton and Dack as well as to the system’s donor; the Town of Englehart.



Notification to system users that the Annual Report is available for viewing is accomplished through:

A notice will be posted on Charlton and Dack's Community Bulletin (CJBB radio) and through discussions during a public council meeting.

2.0 Description of the Drinking Water System (DWS No. 260078741)

The Clarksville Subdivision distribution system is a standalone system that is located in the Municipality of Charlton and Dack, directly adjacent to the northwest boundary of the Town of Englehart. It was constructed in the early 1950's by a private developer, but is owned by each property owner in the subdivision. Based on the number of residential service connections and the fact that the system is jointly owned by the property owners, the Clarksville Subdivision Distribution System is classified as a non-municipal year-round residential drinking water system.

The water mains and appurtenances that comprise this water distribution system are described as follows:

- 2 inch galvanized steel constructed water main that connects to the Englehart Well Supply at the west end of Second Avenue, in the area of the Junction Gas Bar and Restaurant.
- service connections consists of ¾ inch plastic constructed water line.
- no fire hydrants or blow-off valves are located in the system.

The Bradley Subdivision distribution system amalgamated with the Clarksville Subdivision distribution system in August of 2016. The newly amalgamated Bradley Subdivision is a standalone system that joins through a connection at the intersection of Highway 560 and Old Ferguson Highway and is owned by the Municipality of Charlton and Dack

The Bradley Subdivision Distribution System is classified as a small municipal residential drinking water system with a total of 49 service connections.

The map on page 6 illustrates the newly amalgamated Bradley Subidivision.


Donor System

The system connects to and receives all water from the drinking water system owned by the Town of Englehart (DWS # 220000353). The Englehart Drinking Water System is owned by the Corporation of the Town of Englehart. It is a communal ground water well supply that services the Town of Englehart and five neighbouring distribution systems. The Englehart Drinking Water System is operated by the Ontario Clean Water Agency (OCWA). The water treatment facility has a maximum rated capacity of 45.4 liters per second or 2,488 cubic meters per day. It is located on 56 First Street in Evanturel Township in the district of Timiskaming.

The Englehart water system consists of two deep-drilled wells that feed the main treatment building that houses the pressure filtration system, chlorination system, pump station and reservoir. A 150 kW diesel generator is in place and has the capacity to maintain all aspects of the operation during power outages.

More details on the Englehart Drinking Water System are available in the system's 2016 Annual/Summary Report which can be viewed at the Charlton & Dack Municipal Complex or the Englehart Town Office.

Map of the Amalgamated Bradley Subdivision





3.0 List of Water Treatment Chemicals Used Over the Reporting Period

No chemicals are used in the Clarksville Subdivision, however sodium hypochlorite is used for primary disinfection and ammonia sulphate is used in the chloramination process at the Englehart Water Treatment Plant.

4.0 Significant Expenses Incurred in the Drinking Water System

There were no significant installations, replacements or repairs conducted in the system during the reporting period.

5.0 Drinking Water System Highlights

- No MOECC inspections were conducted during the reporting period. The last inspection was done in April 2009.
- Englehart's Chloramination/ammonation system was approved by the Ministry of the Environment's Approval Branch on May 26th. The system has proven effective in maintaining secondary disinfection and reducing trihalomethane (THM) levels in the Clarksville distribution system.
- On August 3, 2016 the MOECC Approvals Branch approved the amalgamation of the Clarksville Subdivision distribution system, a privately owned system, and the Bradley Subdivision distribution system, owned by the Municipality of Charlton and Dack into one system owned by Charlton and Dack. At the same time, an agreement with Municipality of Charlton and Dack and the Town of Englehart also went into effect which sees the Bradley and Englehart distribution systems as one combined system under O. Reg. 170/03. Starting September 5th, 2016, the "new" Bradley distribution system was sampled as part of the Englehart distribution system except for lead sampling under Schedule 15 of O. Reg. 170/03.

6.0 Details on Notices of Adverse Test Results and Other Problems Reported to & Submitted to the Spills Action Center

Based on information kept on record by OCWA, the Clarksville Subdivision distribution system was in full compliance in 2016 with no adverse water quality incidents reported to the MOE's Spills Action Centre.

7.0 Microbiological Testing Performed During the Reporting Period

Summary of Microbiological Data

Sample Type	# of Samples	Range of <i>E. coli</i> Results (min to max)	Range of Total Coliform Results (min to max)	# of HPC Samples	Range of HPC Results (min to max)
Distribution	20	0 to 0	0 to 0	20	<10 to <10

Maximum Allowable Concentration (MAC) for *E. coli* = 0 Counts/100 mL

MAC for Total Coliforms = 0 Counts/100 mL

Notes: Microbiological samples were collected and tested as described in Schedule 11-2 of Ontario Regulation 170/03. At least one distribution sample was taken every two weeks and tested for *E. coli*, Total Coliforms and general bacteria population expressed as colony counts on a heterotrophic plate count (HPC). As of September 5th, microbiological samples were sampled as part of the Englehart distribution system.

“<” denotes less than the laboratory’s method detection limit.

8.0 Operational Testing Performed During the Reporting Period

Summary of Chlorine Residual Data in the Distribution System

Parameter	# of Samples	Range of Results (min to max)	Unit of Measure	Standard
Combined Chlorine Residual	70	0.99 to 2.04	mg/L	0.25

Note: A total of two (2) operational checks for chlorine residual in the distribution system were taken each week. The samples were collected at least 48 hours apart. As of September 5th, combined chlorine residuals were sampled as part of the Englehart distribution system.

Refer to *Appendix A* for a monthly summary of the Microbiological and Chlorine Residual test results.

Summary of Total Trihalomethane Data (sampled in the distribution system)

Date of Sample	Result Value	Unit of Measure	Running Average	Exceedance
January 12	39.5	ug/L	39.9	No
April 11	47.7			
July 11	32.5			
October	see note			

Maximum Allowable Concentration (MAC) for Total Trihalomethanes = 100 ug/L (Four Quarter Running Average)

Note: An agreement with Municipality of Charlton and Dack and the Town of Englehart went into effect In August 2016 which sees the Bradley and Englehart distribution systems as one combined system. Starting on September 5th, THMs were sampled as part of the Englehart distribution system.



Summary of Most Recent Lead Data

(applicable to the following drinking water systems; large municipal residential systems, small, municipal residential systems, and non-municipal year-round residential systems)

The Clarksville Subdivision Distribution System was eligible to follow the “Exemption from Plumbing Sampling” as described in section 15.1-5(9) and 15.1-5(10) of Schedule 15.1 of Ontario Regulation 170/03. The exemption applies to a drinking water system if, in two consecutive periods at reduced sampling, not more than 10% of all samples from plumbing exceed the maximum allowable concentration (MAC) of 10 ug/L for lead. As such, the system was required to test for total alkalinity and pH in one distribution sample collected during the periods of December 15 to April 15 (winter period) and June 15 to October 15 (summer period). This testing is required in every 12-month period with lead testing in every third 12-month period.

Two rounds of alkalinity and pH testing were carried out on April 11th and October 4th of 2016. Results are summarized in the table below.

Summary of pH & Alkalinity Data (sampled in the distribution system)

Date of Sample	# of Samples	Field pH	Field Temperature (°C)	Alkalinity (mg/L)
April 11	1	7.79	4.9	237
October 4 <small>see note</small>	1	7.11	11.5	238

Note: The October samples were collected in the newly amalgamated Bradley Subdivision Distribution System.

Inorganic or Organic Test Results that Exceeded Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.

This section is not applicable to the Clarksville Subdivision Distribution System. Inorganic (Schedule 24) and Organic (Schedule 23) parameters are tested on treated water entering a distribution system.

Summary of Additional Testing Performed in Accordance with a Legal Instrument.

The Englehart drinking water system provides potable water to the Clarksville Subdivision distribution system. On April 8, 2015, the Englehart system was approved to undertake a one-year trial pilot project which involved the implementation of a chloramination/ammoniation process as secondary disinfection and to help reduce THM concentrations in the Englehart distribution system and connected distribution systems.

Additional weekly sampling and testing for monochloramines in the Clarksville Subdivision was a requirement of the donor’s system Drinking Water Works Permit (DWWP 209-201 Schedule C Issue-1). Sampling for free ammonia was also done. A summary of the results are presented below.



Permanent implementation of chloramination/ammoniation system was approved by the Ministry of the Environment's Approval Branch on May 26th. After this date, sampling for monochloramines were no longer a requirement.

Summary of Monochloramine & Free Ammonia Data (sampled as part of the chloramination trial)

Sample Type	# of Monochloramine Samples	Range of Monochloramine Results (min to max)	# of Free Ammonia Samples	Range of Free Ammonia Results (min to max)
Distribution	23	1.05 to 1.58	23	0.03 to 0.21

CONCLUSION

The Clarksville Subdivision Distribution System complied with the regulatory requirements of the Safe Drinking Water Act and its Regulations having no incidents of non-compliance during the reporting period.



APPENDIX A

Monthly Summary of Microbiological and Chlorine
Residual Results

**CLARKSVILLE SUBDIVISION DISTRIBUTION SYSTEM
MONTHLYSUMMARY REPORT**

Facility Org Number: 5049B
 Facility Works Number: 260078741
 Facility Name: CLARKSVILLE SUBDIVISION DISTRIBUTION SYSTEM
 Facility Owner: Other: Private
 Facility Classification: N/A
 From: 01/01/2016 to 04/09/2016

	01/2016	02/2016	03/2016	04/2016	05/2016	06/2016	07/2016	08/2016	09/2016	Total	Avg	Max	Min
Distribution Water / Cl Residual: Combined - mg/L													
Count IH	8	9	8	9	9	9	8	9	1	70			
Max IH	1.73	1.69	1.70	1.85	1.74	2.04	1.85	1.78	1.51			2.04	
Mean IH	1.57	1.45	1.53	1.57	1.47	1.68	1.63	1.65	1.51		1.57		
Min IH	1.39	0.99	1.37	1.38	1.23	1.32	1.13	1.54	1.51				0.99
Distribution Water / E. Coli - cfu/100mL													
Count Lab	2	3	4	2	2	2	2	3	0	20			
Max Lab	0	0	0	0	0	0	0	0				0	
Mean Lab	0	0	0	0	0	0	0	0			0		
Min Lab	0	0	0	0	0	0	0	0					0
Distribution Water / Total Coliform: TC - cfu/100mL													
Count Lab	2	3	4	2	2	2	2	3	0	20			
Max Lab	0	0	0	0	0	0	0	0				0	
Mean Lab	0	0	0	0	0	0	0	0			0		
Min Lab	0	0	0	0	0	0	0	0					0
Distribution Water / HPC - cfu/mL													
Count Lab	2	3	4	2	2	2	2	3	0	20			
Max Lab	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10				10	
Mean Lab	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10			< 10		
Min Lab	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10					< 10